



CSA INTERNATIONAL

Certificate of Compliance

Certificate: 1497596 (LR 43394)

Master Contract: 159930

Project: 1534094

Date Issued: 2004/03/10

Issued to: **R. Stahl, Incorporated**
45 Northwestern Dr
Salem, New Hampshire 03079-4809
USA
Attention: Mr. Winni Faulring

The products listed below are eligible to bear the CSA Mark shown



Issued by: Ron Wildish

Authorized by: Nick Alfano, Operations
Manager

PRODUCTS

CLASS 2258 04 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe, Entity - For Hazardous Locations

Ex nA [ib] IIC:

Intrinsic Safety Barriers, Type 9004; provides intrinsically safe circuits (non-linear) with entity parameters as listed below, when connected per installation drawing 9004611312. These devices must be mounted in a suitable enclosure in non-hazardous locations, Class I, Div. 2 or Class I, Zone 2 hazardous locations (temperature code T4 at Tamb = 60C). Maximum safe area voltage (Um) must not exceed 250Vrms.

Model 9004/0a-086-030-001; with output Entity Parameters $U_o = 8.6V$, $I_o = 30 \text{ mA}$; $P_o = 258 \text{ mW}$.

Model 9004/0a-086-050-001; with output Entity Parameters $U_o = 8.6V$, $I_o = 50 \text{ mA}$; $P_o = 430 \text{ mW}$.



CSA INTERNATIONAL

Certificate: 1497596 (LR 43394)

Master Contract: 159930

Project: 1534094

Date Issued: 2004/03/10

Model 9004/0a-086-100-001; with output Entity Parameters $U_o = 8.6V$, $I_o = 100 \text{ mA}$; $P_o = 860 \text{ mW}$.

Model 9004/0a-086-150-001; with output Entity Parameters $U_o = 8.6V$, $I_o = 150 \text{ mA}$; $P_o = 1290 \text{ mW}$.

Model 9004/0a-168-030-001; with output Entity Parameters $U_o = 16.8V$, $I_o = 30 \text{ mA}$; $P_o = 504 \text{ mW}$.

Model 9004/0a-168-050-001; with output Entity Parameters $U_o = 16.8V$, $I_o = 50 \text{ mA}$; $P_o = 840 \text{ mW}$.

Model 9004/0a-200-030-001; with output Entity Parameters $U_o = 20V$, $I_o = 30 \text{ mA}$; $P_o = 600 \text{ mW}$.

Model 9004/0a-263-025-001; with output Entity Parameters $U_o = 26.3V$, $I_o = 25 \text{ mA}$; $P_o = 657.5 \text{ mW}$.

Model 9004/5a-206-030-001; with output Entity Parameters $U_o = 20.6V$, $I_o = 30 \text{ mA}$; $P_o = 618 \text{ mW}$.

Model 9004/5a-220-030-001; with output Entity Parameters $U_o = 22V$, $I_o = 30 \text{ mA}$; $P_o = 660 \text{ mW}$.

Note: 1. $a = 0$ for negative; 1 for positive polarity type

2. For further details on Certification parameters, see Descriptive and Test Report.

Ex nA [ib] IIB:

Intrinsic Safety Barriers, Type 9004; provides intrinsically safe circuits (non-linear) with entity parameters as listed below, when connected per installation drawing 9004611312. These devices must be mounted in a suitable enclosure in non-hazardous locations, Class I, Div. 2 or Class I, Zone 2 hazardous locations (temperature code T4 at $T_{amb} = 60C$). Maximum safe area voltage (U_m) must not exceed 250Vrms.

Model 9004/0a-168-100-001; with output Entity Parameters $U_o = 16.8V$, $I_o = 100 \text{ mA}$; $P_o = 1680 \text{ mW}$.

Model 9004/0a-172-140-001; with output Entity Parameters $U_o = 17.2V$, $I_o = 140 \text{ mA}$; $P_o = 2408 \text{ mW}$.

Model 9004/0a-200-050-001; with output Entity Parameters $U_o = 20V$, $I_o = 50 \text{ mA}$; $P_o = 1000 \text{ mW}$.

Model 9004/0a-200-095-001; with output Entity Parameters $U_o = 20V$, $I_o = 95 \text{ mA}$; $P_o = 1900 \text{ mW}$.

Model 9004/0a-263-030-001; with output Entity Parameters $U_o = 26.3V$, $I_o = 30 \text{ mA}$; $P_o = 789 \text{ mW}$.

Model 9004/0a-263-050-001; with output Entity Parameters $U_o = 26.3V$, $I_o = 50 \text{ mA}$; $P_o = 1315 \text{ mW}$.

Model 9004/0a-280-025-001; with output Entity Parameters $U_o = 28V$, $I_o = 25 \text{ mA}$; $P_o = 700 \text{ mW}$.

Model 9004/0a-280-045-001; with output Entity Parameters $U_o = 28V$, $I_o = 45 \text{ mA}$; $P_o = 1260 \text{ mW}$.

Model 9004/0a-315-022-001; with output Entity Parameters $U_o = 31.5V$, $I_o = 22 \text{ mA}$; $P_o = 693 \text{ mW}$.

Model 9004/0a-315-025-001; with output Entity Parameters $U_o = 31.5V$, $I_o = 25 \text{ mA}$; $P_o = 787.5 \text{ mW}$.



CSA INTERNATIONAL

Certificate: 1497596 (LR 43394)

Master Contract: 159930

Project: 1534094

Date Issued: 2004/03/10

Model 9004/5a-206-050-001; with output Entity Parameters $U_o = 20.6V$, $I_o = 50 \text{ mA}$; $P_o = 1030 \text{ mW}$.

Model 9004/5a-206-085-001; with output Entity Parameters $U_o = 20.6V$, $I_o = 85 \text{ mA}$; $P_o = 1751 \text{ mW}$.

Notes: 1. $a = 0$ for negative; 1 for positive polarity type

2. For further details on Certification parameters, see Descriptive and Test Report.

Ex nA [ib] IIC:

Class I, Groups A, B, C and D; Class II, Groups E, F and G; Class III:

Intrinsic Safety Barriers, Type 9004; provides intrinsically safe circuits with entity parameters as listed below, when connected per installation drawing 9004611312. These devices must be mounted in a suitable enclosure in non-hazardous locations, Class I, Div. 2 or Class I, Zone 2 hazardous locations (temperature code T4 at $T_{amb} = 60C$). Maximum safe area voltage (U_m) must not exceed 250Vrms.

Model 9004/61-220-035-001; with output Entity Parameters $U_o = 22V$, $I_o = 35 \text{ mA}$; $P_o = 770 \text{ mW}$.

Model 9004/61-232-028-041; with output Entity Parameters $U_o = 23.2V$, $I_o = 28 \text{ mA}$; $P_o = 649.6 \text{ mW}$.

Note: For further details on Certification parameters, see Descriptive and Test Report.

APPLICABLE REQUIREMENTS

CAN/CSA-E60079-0:02 - Electrical Apparatus for Explosive Gas Atmospheres??Part 0: General Requirements

CAN/CSA- E60079-11:02 - Electrical apparatus for explosive gas atmospheres, Part 11: Intrinsic safety "i"

CAN/CSA-E60079-15:02 - Electrical apparatus for explosive gas atmospheres, Part 15: Electrical apparatus with type of protection "n"

CSA Std C22.2 No. 213-M1987 - Non-incendive Electrical Equipment for use in Class I, Division 2 Hazardous Locations

CAN/CSA- No. 157-92 - Intrinsically Safe and Non-incendive Electrical Equipment for Use in Hazardous Locations



CSA INTERNATIONAL

Supplement to Certificate of Compliance

Certificate: 1497596

Master Contract: 159930

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
1534094	2004/03/10	Update of Report 1497596 to Cover Report Corrections
1497596	2004/01/09	Original Certification. New Generation of Safety Barriers for Hazardous Locations

The copying, distribution and utilization of this document as well as the communication of its contents to others without expressed authorization is prohibited. Offenders will be held liable for the payment of damages. All rights reserved in the event of the grant of a patent, utility model or ornamental design registration.

For Safety barriers
9004/0-.....-1 and
9004/5-.....-1
(see Table 1)

Class I, Zone 1; Group IIC/IIB
 Hazardous Locations


Non-hazardous or Zone 2
 Hazardous Locations

For Safety barriers
9004/61-.....-1
(see Table 2)

Class I, II, III; Div. 1; Group A-G
 or Class I; Zone 1; Group IIC/IIB
 Hazardous Locations

Non-hazardous, Division 2 or Zone 2
 Hazardous Locations

Intrinsic Safe Apparatus
or Simple Apparatus



Notes:

- Intrinsically safe apparatus may be switches, thermocouples, LEDs, RTDs or a CSA Certified System or Entity device connected in accordance with the manufacturer's installation instructions.
- For Entity concept use the appropriate parameters to ensure the following:
 - for Divisions:

$V_{OC} \leq V_{max}$	$C_a \geq C_i + C_{leads}$
$I_{SC} \leq I_{max}$	$L_a \geq L_i + L_{leads}$
 - for Zones:

$U_o \leq U_i$	$C_o \geq C_i + C_{leads}$
$I_o \leq I_i$	$L_o \geq L_i + L_{leads}$
- Electrical apparatus connected to an intrinsically safe system should not use or generate voltages > 250 V (U_{max}).
- Installation should be in accordance with the Canadian Electrical Code, Part I.
- The system shall be installed in a suitable enclosure per the Authority Having Jurisdiction..
- Maximum barrier operating temperature is 60 °C.

WARNING – DO NOT DISCONNECT NON-INTRINSICALLY SAFE WIRING OR REPLACE FUSES UNLESS POWER HAS BEEN SWITCHED OFF OR THE AREA IS KNOWN TO BE NON-HAZARDOUS.

Certification drawing

		2003		Date	Name	Title	Scale
		Drawn	21.07.		T. Walter	INTRINSPAK Series 9004/.....-1 Intrinsic Safety Barriers	none
		Appr.			Kaiser		Sheet
						Drawing No.	1 of 2
						90 046 11 31 2	
01	03.11.03	T. Stahl				Replaces:	CSA
Index	Date	Drawn				90 046 11 31 2	

Safety Barriers Types 9004/0.-.....1 and 9004/5.-.....1

The Intrinsic Safety Barriers Types 9004/0. and 9004/5. are associated apparatus located in a non-hazardous or Zone 2 locations and provide intrinsically safe connections for device(s) located in Class I, Zone 1, Group IIC/IIB Hazardous (Classified) Locations.

Table 1 - Barrier Types and Parameters suitable for Zone 1 Installations:

Type	U _O [V]	I _O [mA]	P _O [mW]	Group IIC		Group IIB	
				L _O [mH]	C _O [μF]	L _O [mH]	C _O [μF]
9004/0a-086-030-001	8.6	30	258	2.0	0.86	2.5	5.0
9004/0a-086-050-001	8.6	50	430	2.0	0.69	2.5	4.5
9004/0a-086-100-001	8.6	100	860	1.0	0.63	2.5	3.4
9004/0a-086-150-001	8.6	150	1290	0.97	0.38	2.5	2.3
9004/0a-168-030-001	16.8	30	504	2.0	0.22	2.5	1.3
9004/0a-168-050-001	16.8	50	840	0.86	0.16	2.5	1.2
9004/0a-168-100-001	16.8	100	1680	-	-	1.6	1.1
9004/0a-172-140-001	17.2	140	2408	-	-	0.17	1.2
9004/0a-200-030-001	20	30	600	2.0	0.082	2.5	0.80
9004/0a-200-050-001	20	50	1000	-	-	2.5	0.68
9004/0a-200-095-001	20	95	1900	-	-	0.2	0.88
9004/0a-263-025-001	26.3	25	657.5	0.17	0.097	2.5	0.33
9004/0a-263-030-001	26.3	30	789	-	-	2.5	0.31
9004/0a-263-050-001	26.3	50	1315	-	-	1.3	0.33
9004/0a-280-025-001	28	25	700	-	-	2.5	0.28
9004/0a-280-045-001	28	45	1260	-	-	1.5	0.28
9004/0a-315-022-001	31.5	22	693	-	-	2.5	0.24
9004/0a-315-025-001	31.5	25	787.5	-	-	2.5	0.23
9004/5a-206-030-001	20.6	30	618	2.0	0.072	2.5	0.72
9004/5a-206-050-001	20.6	50	1030	-	-	2.5	0.58
9004/5a-206-085-001	20.6	85	1751	-	-	0.37	0.68
9004/5a-220-030-001	22	30	660	1.3	0.073	2.5	0.55

a = Polarity: 0 (negative) or 1 (positive)

Safety Barriers Types 9004/61-.....1

The Intrinsic Safety Barriers Types 9004/61 are associated apparatus located in a non-hazardous or Div. 2 or Zone 2 locations and provide intrinsically safe connections for device(s) located in Class I, Div. 1, Group A, B, C, D; Class II, Div. 1, Group E, F, G; Class III, Div. 1; or Class I, Zone 1, Group IIC/IIB Hazardous (Classified) Locations.


Table 2 - Barrier Types and Parameters suitable for Division 1 and Zone 1 Installations

Type	V _{OC} (U _O) [V]	I _{SC} (I _O) [mA]	P _O [mW]	Group A, B, E Group IIC		Group C, D, F, G Group IIB	
				L _O / L _a [mH]	C _O / C _a [μF]	L _O / L _a [mH]	C _O / C _a [μF]
9004/61-220-035-001	22	35	770	0.05	0.165	2.5	0.52
9004/61-232-028-041	23.2	28	649.6	1.0	0.075	2.5	0.46

The copying, distribution and utilization of this document as well as the communication of its contents to others without expressed authorization is prohibited. Offenders will be held liable for the payment of damages. All rights reserved in the event of the grant of a patent, utility model or ornamental design registration.

Weitergabe sowie Vervielfältigung dieses Dokuments, Verwertung und Mitteilung seines Inhalts sind verboten, soweit nicht ausdrücklich gestattet. Zuwiderhandlungen verpflichten zu Schadensersatz. Alle Rechte für den Fall der Patent-, Gebrauchsmuster- oder Geschmacksmustereintragung vorbehalten.

Certification drawing

		2003		Date	Name	Title INTRINSPAK Series 9004/.....1 Intrinsic Safety Barriers	Scale none
		Drawn	21.07.	T. Walter	Kaiser		Sheet 2 of 2
		Appr.					
01	03.11.03	T. Stahl			Drawing No.	90 046 11 31 2	Agency CSA
Index	Date	Drawn			Replaces:	Replaced by:	A4