



Member of the FM Global Group

FM Approvals
1151 Boston-Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781 762 9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

I. Intrinsically Safe Outputs

9411/21-2a0-b1, Field Device Coupler

NI/I/2/ABCD/T4 Ta = 75°C

AIS/I, II, III/1/ABCDEFGH; 9411 6 031 002 1; Entity

I/1/ AEx m e [ia]/IIC/T4 Ta = 75°C; 9411 6 031 001 1; Entity

a = Connector design: 1 or 2

b = Channels: 3 or 4

Entity Parameters:

Voc = 15.7VDC, Isc = 245mA, Ca = 476nF, La = 0.58mH, Lo/Ro = 37μH/Ω

Special Conditions of Use

1. Shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.

II. Intrinsically Safe Outputs With Optional Enclosures

9411/21-2ab-c1, Field Device Coupler

NI/I/2/ABCD/T4 Ta = 70°C; IP54

DIP/II, III/1,2/ EFG/T4 Ta = 70°C; IP54

AIS/I, II, III/1/ABCDEFGH; 9411 6 031 002 1; Entity

I/1/ AEx m e [ia]/IIC/T4 Ta = 70°C; 9411 6 031 001 1; Entity; IP54

a = Connector design: 1 or 2

b = Enclosure: 3 or 4

c = channels: 3 or 4

Entity Parameters:

Voc = 15.7VDC, Isc = 245mA, Ca = 476nF, La = 0.58mH, Lo/Ro = 37μH/Ω

Special Conditions of Use

1. For enclosure options 3, bonding between the conduit hubs shall be required.

III. Non-Intrinsically Safe Outputs

9411/11-2a0-b0, Field Device Coupler

NI/II/2/ABCD/T4 Ta = 75°C

I/1/Ex m e/IIC/T4 Ta = 75°C; 9411 6 031 002 1;

a = Connector design: 1 or 2

b = Channels: 3 or 4

Special Conditions of Use

1. *Shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.*

IV. Non-Intrinsically Safe Outputs With Optional Enclosures

9411/11-2ab-c0, Field Device Coupler

NI/II/2/ABCD/T4 Ta = 70°C; IP54

DIP/II, III/1,2/ EFG/T4 Ta = 70°C; IP54

I/1/Ex m e/IIC/T4 Ta = 70°C; 9411 6 031 002 1; IP54

a = Connector design: 1 or 2

b = Enclosure: 3 or 4

c = channels: 3 or 4

Special Conditions of Use

1. *For enclosure options 3, bonding between the conduit hubs shall be required.*

Equipment Ratings:

I. Intrinsically Safe Outputs

Nonincendive for Class I, Division 2, Groups A, B, C & D,

Increased Safety and Encapsulation for use in Class I, Zone 1, Group IIC;

Hazardous (Classified) indoor/outdoor (IP54) Locations

Intrinsically Safe Outputs, with entity parameters, for Connections to Class I, II & III, Division 1, Groups A, B, C, D, E, F & G, and Class I, Zone 0, Group IIC, in accordance with manufacturer's Control Drawing No. 9411 6 031 002 1

II. Intrinsically Safe Outputs With Optional Enclosures

Nonincendive for Class I, Division 2, Groups A, B, C & D,

Increased Safety and Encapsulation for use in Class I, Zone 1, Group IIC;

Suitable for Class II, Division 2, Groups E, F & G

Dust-Ignition Proof for Class II & III, Division 1, Groups E, F & G

Hazardous (Classified) indoor/outdoor (TYPE 4X, IP54) Locations

Intrinsically Safe Outputs, with entity parameters, for Connections to Class I, II & III, Division 1, Groups A, B, C, D, E, F & G, and Class I, Zone 0, Group IIC, in accordance with manufacturer's Control Drawing No. 9411 6 031 002 1

III. Non-Intrinsically Safe Outputs

Nonincendive for Class I, Division 2, Groups A, B, C & D,

Increased Safety and Encapsulation for use in Class I, Zone 1, Group IIC;

Hazardous (Classified) indoor/outdoor (IP54) Locations



IV. Non-Intrinsically Safe Outputs With Optional Enclosures

Nonincendive for Class I, Division 2, Groups A, B, C & D,
Increased Safety and Encapsulation for use in Class I, Zone 1, Group IIC;
Suitable for Class II, Division 2, Groups E, F & G
Dust-Ignition Proof for Class II & III, Division 1, Groups E, F & G
Hazardous (Classified) indoor/outdoor (TYPE 4X, IP54) Locations

FM Approved for:

R. STAHL Schaltgeraete GmbH
Am Bahnhof 30
D-74638 Waldenburg (Wurt.) Germany

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

| | |
|-------------------|------|
| Class 3600 | 1998 |
| Class 3610 | 1999 |
| Class 3611 | 1999 |
| Class 3615 | 1989 |
| Class 3810 | 2005 |
| ANSI/ISA-12.23.01 | 2002 |
| ANSI/ISA-12.16.01 | 2002 |
| IEC 60529 | 2001 |


Original Project ID: 3026646

Approval Granted: *July 11, 2006* 

Subsequent Revision Reports / Date Approval Amended

| Report Number | Date | Report Number | Date |
|---------------|------|---------------|------|
|---------------|------|---------------|------|

FM Approvals LLC



Richard B. Dunne
Group Manager

July 11, 2006
Date